

STATE OF CALIFORNIA
CALIFORNIA REGIONAL WATER QUALITY CONTROL BOARD
LOS ANGELES REGION
320 West 4th Street, Suite 200, Los Angeles, California 90013

FACT SHEET
WASTE DISCHARGE REQUIREMENTS
FOR
SOUTHERN CALIFORNIA GAS COMPANY
(LOS ALAMITOS PRESSURE LIMITING STATION REPLACEMENT)

NPDES NO. CAG674001
CI-8419

FACILITY ADDRESS

Intersection of Hwy 22 and N. Studebaker Rd.
Long Beach, California

FACILITY MAILING ADDRESS

555 W. Fifth Street
Los Angeles, CA 90013

PROJECT DESCRIPTION:

Southern California Gas Company (Gas Company) proposes to discharge hydrostatic test water from Los Alamitos Pressure Limiting Station Project located at the intersection of Highway 22 and Studebaker Road, Long Beach. The project includes the construction and hydrostatic testing of 150 feet of pipeline. The pipeline will be used for gas feed for the AES Los Alamitos Steam Plant. The Gas Company will use potable water supplied by the City of Long Beach during the hydrostatic testing.

VOLUME AND DESCRIPTION OF DISCHARGE:

A total of approximately 6,000 gallons of hydrostatic water will be discharged to the San Gabriel River (Latitude: 33° 46' 26", Longitude: 118° 5' 53") a water of the United States. The hydrostatic testing of the new pipelines will be conducted in three phases. In order to minimize the amount of water to be discharged, the hydrostatic water will be reused through the completion of the various phases of the project. The hydrostatic test water will be collected in a holding tank at the end of the hydrostatic testing. The project location map is shown in Figure 1.

FREQUENCY OF DISCHARGE:

The hydrostatic test water will be collected into a holding tank and will be discharged at the completion of the various phases of the project.

REUSE OF WATER:

The water will be reused for dust suppression and the remaining water will be discharged into the San Gabriel River.